

Bologna, 28/01/2016

Messrs

LAPITEC S.p.a
Via Bassanese, 6
31050 Veduggio (TV)

TEST LABORATORY

TEST REPORT No. 2113/16

Requested by:	LAPITEC S.p.a Via Bassanese, 6 31050 Veduggio (TV)
On (date):	18/01/16
For the sample marked:	"Lapitec Sintered Stone DUNE"

The results reported relate only to the samples tested.

No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision.

The reproduction of this test report is only authorized in the form of a complete photographic facsimile.

Our written approval is necessary for any partial reproduction.

This test report consists of 3 pages this cover included.



CENTRO CERAMICO

Test Report No. 2113/16

Date 28/01/2016

Page 2 of 3

Description of the sample:	Lastre di materiale lapideo 50x120x1,2 cm contrassegnato "Lapitec Sintered Stone DUNE".
Manufacturer:	-----
Sampling details	
- Where:	-----
- Date:	-----
- By whom:	CUSTOMER
- How (methods):	-----
Date of receipt in laboratory:	19/01/16

TESTS PERFORMED :


<input checked="" type="checkbox"/>	DIN 51097 (92)	Slip resistance	Date of starting	Date of ending
			28/01/16	28/01/16

DIN 51097 (92) - Slip resistance

- Size of the tested surface (m) 0.50 x 1.20
- Joint width (mm): ---
- Grout: ---

OPERATIVE CONDITIONS

Fixing scheme

**RESULTS**

- Average slip angle:

20°**CLASSIFICATION (BGI/GUV-I 8527- 2010)**

- Evaluation group:

A+B

Pietro Bruzzi
Technical verification



Prof. Maria Chiara Bignozzi

Director

